



CENTRALINA DI RIARMO ELETTRICA

La centralina è azionata tramite un quadro elettrico di comando costruito secondo le normative CEI – IEC fornito con certificato di collaudo e marcatura CE di compatibilità elettromagnetica.

Costruito con le seguenti caratteristiche standard:

- Quadro stagno IP55 in poliestere
- Alimentazione dei circuiti di potenza (elettropompe) 220/400V – 3 – 50 Hz
- Alimentazione ausiliaria (elettrovalvole) 24V c.c.
- Interruttore generale con blocco porta
- Comando apertura/chiusura manuale
- Indicatore valvola chiusa/aperta/superamento velocità
- Allarmi vari

A richiesta

- Predisposizione per la trasmissione a distanza dei segnali di comando e di allarme.

ELECTRIC RESETTING UNIT

The above mentioned oleodynamic unit is operated by an electric control board made according to CEI – IEC standards, supplied with test certificates and CE mark, including standard features:

- *Polyester IP55 proof cabinet*
- *Feeder of motor pumps: 220/400V – 3 – 50 Hz*
- *Feeder of auxiliary units (solenoid valves): 24V c.c.*
- *Cut-off switch with door clamping device*
- *Manual opening/closing push bottoms*
- *Manual/automatic operation selector*
- *Open/close valve, excess velocity indicator*
- *Alarms*

Optional

- *Prearrangement for remote control and alarm*

